

Viktig information:



Montering av typgodkänd brandskyddsprodukt

För att säkerställa att det installerade brandskyddet bibehåller sin typgodkända status, är det avgörande att installationen sker i enlighet med den angivna monteringsanvisningen.

Om installationen utförs på ett sätt som avviker från monteringsanvisningen, kommer brandskyddet inte längre att vara typgodkänt.

Användningsområden

Brandnätet INCA WFS net är typgodkänt för att förhindra spridning av brand och brandgaser i luftspalter på 25-45 mm. Det kan användas i följande applikationer:

- **Ventilerad takfot** (EI 30 / EI 45 / E 60)
- **Bakom fasadbeklädnad** (EI 30 / EI 45 / E 60)
- **I höjd med syll** (EI 30 / EI 45 / E 60)
- **I nivå med bjälklag** (EI 30 / EI 45 / E 60)

Brandnätet INCA WFS net är också typgodkänt som brandventil med brandklass EI 30 i följande områden:

- **Dold takfot** (EI 30)
- **Undertak** (EI 30)
- **Överluftsdon** (EI 30)

För att säkerställa korrekt installation, skanna QR-koden här intill för att få tillgång till monteringsanvisningarna.

För ytterligare frågor eller support angående installationen, vänligen kontakta oss .

Flameguard Brandskydd

Tel: 020-12 12 21

Web: flameguard.se

Monteringsanvisningar



Important Information:



Installation of a certified fire protection product

To ensure that the installed fire protection retains its certified status, it is crucial that the installation is carried out in accordance with the specified installation instructions.

If the installation is performed in a manner that deviates from the instructions, the fire protection will no longer be certified.

Applications

The INCA WFS net is certified to prevent the spread of fire and fire gases in cavities between 25-45 mm. It can be used in the following applications:

- **Ventilated eaves** (EI 30 / EI 45 / E 60)
- **Behind façade cladding** (EI 30 / EI 45 / E 60)
- **At the base of walls** (EI 30 / EI 45 / E 60)
- **At floor levels** (EI 30 / EI 45 / E 60)

The INCA WFS net is also certified as a fire vent with a fire rating of EI 30 in the following areas:

- **Closed soffits** (EI 30)
- **Suspended ceilings** (EI 30)
- **Air transfer grilles** (EI 30)

Installation Instructions



For correct installation, scan the QR code next to this text to access the installation instructions.

For further questions or support regarding the installation, please contact us.

Flameguard Brandskydd

Tel: 020-12 12 21

Web: flameguard.se

inca | **WFS net**[®]
by flameguard